

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

July 5, 2022

Fairview Board of Education
130 Hamilton Avenue
Fairview, NJ 07022
Attn.: Mr. John Bussanich
Business Administrator

Re: Lead in Drinking Water Analysis at Fairview Board of Education – Lincoln School – Fairview, New Jersey

Dear John:

Pursuant to your request, in regards to the above referenced subject, **RAMM Environmental Services, Inc.** is pleased to submit to you our report including findings, analysis and recommendations.

Should you have any questions or need additional information, please feel free to call upon me at (201) 475-9880. Thank you very much.

Respectfully submitted,
RAMM Environmental Services, Inc.

Rodger Headrick

Rodger Headrick, CMRS
President

fh

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

**LEAD IN DRINKING WATER ANALYSIS
FOR
FAIRVIEW BOARD OF EDUCATION
LINCOLN SCHOOL
FAIRVIEW, NEW JERSEY
JUNE 17, 2022**

**Prepared for:
Fairview Board of Education
130 Hamilton Avenue
Fairview, NJ 07022
Attn.: Mr. John Bussanich
Business Administrator
Tel: (201) 943-0201
Fax: (201) 941-1195**

**Prepared by:
RAMM Environmental Services, Inc.
77 Nottingham Road, PO Box 308
Fair Lawn, NJ 07410
Mr. Rodger Headrick
President
Tel: (201) 475-9880
Fax: (201) 475-9881**

July 5, 2022

REPORT CONTENTS

INTRODUCTION	1
WATER QUALITY MONITORING RESULTS	2
RECOMMENDATIONS	3
APPENDIX	
Lead in Drinking Water Certificate of Analysis	

INTRODUCTION

RAMM Environmental Services, Inc. was requested by the Fairview Board of Education to perform water sampling for lead content at the Lincoln School located in Fairview, New Jersey.

Water quality sampling functions were performed by RAMM at the Lincoln School located in Fairview, New Jersey on June 17, 2022, to determine the quality of drinking water for lead content. Water sampling began in the morning, after all water outlets had remained unused for a minimum of eight (8) hours.

**WATER QUALITY MONITORING RESULTS
LEAD IN DRINKING WATER ANALYSIS**

Lead in drinking water sampling was performed during RAMM's June 17, 2022 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

Lincoln School

Lead in drinking water measurements were collected in seven (7) locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
Field Blank	Field Blank	None Detected
22-0617-01	Kitchen (Sink)	2.33 ppb
22-0617-02	Basement Hallway (Water Fountain)	None Detected
22-0617-03	1 st Floor Hallway by Room 106 (Water Fountain)	None Detected
22-0617-04	Nurse Room (Sink)	None Detected
22-0617-05	Faculty Room (Sink)	None Detected
22-0617-06	2 nd Floor Hallway by Room 206 (Water Fountain)	None Detected
22-0617-07	Gonzalez Office (Sink)	None Detected

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants.

RECOMMENDATIONS

Continue operation and maintenance as normal. Re-test all drinking water outlets during the 2024-2025 school year.

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
“Non-Friable” Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

July 5, 2022

Fairview Board of Education
130 Hamilton Avenue
Fairview, NJ 07022
Attn.: Mr. John Bussanich
Business Administrator

**Re: Lead in Drinking Water Analysis at Fairview Board of Education – Lincoln
School Annex – Fairview, New Jersey**

Dear John:

Pursuant to your request, in regards to the above referenced subject, **RAMM Environmental Services, Inc.** is pleased to submit to you our report including findings, analysis and recommendations.

Should you have any questions or need additional information, please feel free to call upon me at (201) 475-9880. Thank you very much.

Respectfully submitted,
RAMM Environmental Services, Inc.

Rodger Headrick

Rodger Headrick, CMRS
President

fh

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

July 5, 2022

Fairview Board of Education
130 Hamilton Avenue
Fairview, NJ 07022
Attn.: Mr. John Bussanich
Business Administrator

**Re: Lead in Drinking Water Analysis at Fairview Board of Education – School
No. 3 – Fairview, New Jersey**

Dear John:

Pursuant to your request, in regards to the above referenced subject, **RAMM Environmental Services, Inc.** is pleased to submit to you our report including findings, analysis and recommendations.

Should you have any questions or need additional information, please feel free to call upon me at (201) 475-9880. Thank you very much.

Respectfully submitted,
RAMM Environmental Services, Inc.

Rodger Headrick

Rodger Headrick, CMRS
President

fh

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

**LEAD IN DRINKING WATER ANALYSIS
FOR
FAIRVIEW BOARD OF EDUCATION
SCHOOL NO. 3
FAIRVIEW, NEW JERSEY
JUNE 17, 2022**

**Prepared for:
Fairview Board of Education
130 Hamilton Avenue
Fairview, NJ 07022
Attn.: Mr. John Bussanich
Business Administrator
Tel: (201) 943-0201
Fax: (201) 941-1195**

**Prepared by:
RAMM Environmental Services, Inc.
77 Nottingham Road, PO Box 308
Fair Lawn, NJ 07410
Mr. Rodger Headrick
President
Tel: (201) 475-9880
Fax: (201) 475-9881**

July 5, 2022

REPORT CONTENTS

INTRODUCTION	1
WATER QUALITY MONITORING RESULTS	2
RECOMMENDATIONS	3
APPENDIX	
Lead in Drinking Water Certificate of Analysis	

INTRODUCTION

RAMM Environmental Services, Inc. was requested by the Fairview Board of Education to perform water sampling for lead content at the School No. 3 located in Fairview, New Jersey.

Water quality sampling functions were performed by RAMM at the School No. 3 located in Fairview, New Jersey on June 17, 2022, to determine the quality of drinking water for lead content. Water sampling began in the morning, after all water outlets had remained unused for a minimum of eight (8) hours.

**WATER QUALITY MONITORING RESULTS
LEAD IN DRINKING WATER ANALYSIS**

Lead in drinking water sampling was performed during RAMM's June 17, 2022 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

School No. 3

Lead in drinking water measurements were collected in fourteen (14) locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
Field Blank	Field Blank	None Detected
22-0617-01	Cafeteria (Water Fountain)	2.02 ppb
22-0617-02	1 st Floor Hallway by Room 101 (Water Fountain)	None Detected
22-0617-03	Bathroom Inside Room 101 (Sink)	1.33 ppb
22-0617-04	1st Floor Hallway by Room 104 (Water Fountain)	None Detected
22-0617-05	2 nd Floor Hallway by Room 202 (Water Fountain)	None Detected
22-0617-06	2 nd Floor Hallway by Room 204 (Water Fountain)	None Detected
22-0617-07	Faculty Room (Sink)	5.92 ppb
22-0617-08	3 rd Floor on Left (Water Fountain)	None Detected
22-0617-09	3 rd Floor on Right (Water Fountain)	None Detected
22-0617-10	Trailer Left (Water Fountain)	None Detected
22-0617-11	Trailer Right (Water Fountain)	None Detected
22-0617-12	Trailer Boys Bathroom (Sink)	None Detected
22-0617-13	Trailer Girls Bathroom (Sink)	None Detected
22-0617-14	Trailer Faculty Bathroom (Sink)	None Detected

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants.

RECOMMENDATIONS

Continue operation and maintenance as normal. Re-test all drinking water outlets during the 2024-2025 school year.

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

**LEAD IN DRINKING WATER ANALYSIS
FOR
FAIRVIEW BOARD OF EDUCATION
LINCOLN SCHOOL ANNEX
FAIRVIEW, NEW JERSEY
JUNE 17, 2022**

**Prepared for:
Fairview Board of Education
130 Hamilton Avenue
Fairview, NJ 07022
Attn.: Mr. John Bussanich
Business Administrator
Tel: (201) 943-0201
Fax: (201) 941-1195**

**Prepared by:
RAMM Environmental Services, Inc.
77 Nottingham Road, PO Box 308
Fair Lawn, NJ 07410
Mr. Rodger Headrick
President
Tel: (201) 475-9880
Fax: (201) 475-9881**

July 5, 2022

REPORT CONTENTS

INTRODUCTION	1
WATER QUALITY MONITORING RESULTS	2
RECOMMENDATIONS	3
APPENDIX	
Lead in Drinking Water Certificate of Analysis	

INTRODUCTION

RAMM Environmental Services, Inc. was requested by the Fairview Board of Education to perform water sampling for lead content at the Lincoln School Annex located in Fairview, New Jersey.

Water quality sampling functions were performed by RAMM at the Lincoln School Annex located in Fairview, New Jersey on June 17, 2022, to determine the quality of drinking water for lead content. Water sampling began in the morning, after all water outlets had remained unused for a minimum of eight (8) hours.

**WATER QUALITY MONITORING RESULTS
LEAD IN DRINKING WATER ANALYSIS**

Lead in drinking water sampling was performed during RAMM's June 17, 2022 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

Lincoln School Annex

Lead in drinking water measurements were collected in five (5) locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
Field Blank	Field Blank	None Detected
22-0617-01	2 nd Floor Hallway by Room B2 (Water Fountain)	None Detected
22-0617-02	Nurse Room (Sink)	None Detected
22-0617-03	2 nd Floor Faculty Room (Sink)	None Detected
22-0617-04	1 st Floor by Bathroom (Water Fountain)	None Detected
22-0617-05	Superintendent Office (Sink)	None Detected

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants.

RECOMMENDATIONS

Continue operation and maintenance as normal. Re-test all drinking water outlets during the 2024-2025 school year.

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
“Non-Friable” Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

July 5, 2022

Fairview Board of Education
130 Hamilton Avenue
Fairview, NJ 07022
Attn.: Mr. John Bussanich
Business Administrator

**Re: Lead in Drinking Water Analysis at Fairview Board of Education – School
No. 3 Annex – Fairview, New Jersey**

Dear John:

Pursuant to your request, in regards to the above referenced subject, **RAMM Environmental Services, Inc.** is pleased to submit to you our report including findings, analysis and recommendations.

Should you have any questions or need additional information, please feel free to call upon me at (201) 475-9880. Thank you very much.

Respectfully submitted,
RAMM Environmental Services, Inc.

Rodger Headrick

Rodger Headrick, CMRS
President

fh

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

**LEAD IN DRINKING WATER ANALYSIS
FOR
FAIRVIEW BOARD OF EDUCATION
SCHOOL NO. 3 ANNEX
FAIRVIEW, NEW JERSEY
JUNE 17, 2022**

**Prepared for:
Fairview Board of Education
130 Hamilton Avenue
Fairview, NJ 07022
Attn.: Mr. John Bussanich
Business Administrator
Tel: (201) 943-0201
Fax: (201) 941-1195**

**Prepared by:
RAMM Environmental Services, Inc.
77 Nottingham Road, PO Box 308
Fair Lawn, NJ 07410
Mr. Rodger Headrick
President
Tel: (201) 475-9880
Fax: (201) 475-9881**

July 5, 2022

REPORT CONTENTS

INTRODUCTION	1
WATER QUALITY MONITORING RESULTS	2
RECOMMENDATIONS	3
APPENDIX	
Lead in Drinking Water Certificate of Analysis	

INTRODUCTION

RAMM Environmental Services, Inc. was requested by the Fairview Board of Education to perform water sampling for lead content at the School No. 3 Annex located in Fairview, New Jersey.

Water quality sampling functions were performed by RAMM at the School No. 3 Annex located in Fairview, New Jersey on June 17, 2022, to determine the quality of drinking water for lead content. Water sampling began in the morning, after all water outlets had remained unused for a minimum of eight (8) hours.

**WATER QUALITY MONITORING RESULTS
LEAD IN DRINKING WATER ANALYSIS**

Lead in drinking water sampling was performed during RAMM’s June 17, 2022 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

School No. 3 Annex

Lead in drinking water measurements were collected in eight (8) locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
Field Blank	Field Blank	None Detected
22-0617-01	Kitchen (Sink 01)	18.1 ppb
22-0617-02	Kitchen (Sink 02)	7.11 ppb
22-0617-03	Kitchen (Sink 03)	7.3 ppb
22-0617-04	Nurse Room (Sink)	None Detected
22-0617-05	1 st Floor Hallway by Nurse Room (Water Fountain)	None Detected
22-0617-06	Room A-2 (Sink)	1.0 ppb
22-0617-07	Faculty Room (Sink)	3.28 ppb
22-0617-08	2 nd Floor Hallway by Room B-4 (Water Fountain)	None Detected

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants, with the exception of drinking water at the following location:

School No. 3 Annex – Kitchen (Sink 01).

RECOMMENDATIONS

Kitchen (Sink 01): Turn off water to sink. Hire plumber to remove all lead containing welding solder (if any) from copper water pipes, flush. Upon completion of work operate follow-up Lead in Drinking Water Sampling and Analysis.